

Norme di COLLAUDO

SECONDO EN 12266-1 / ISO 5208 / EN ISO 17292 / API6D-ISO 14313

PN	PROVA IDROSTATICA		PROVA PNEUMATICA bar
	CORPO bar	TENUTA bar	
10	15,0	11,0	6,0
16	24,0	18,0	6,0
25	38,0	28,0	6,0
40	60,0	44,0	6,0
64	96,0	71,0	6,0
100	150,0	110,0	6,0
160	240,0	176,0	6,0
250	375,0	275,0	6,0
420	630,0	462,0	6,0

SECONDO EN 12266-1 / ISO 5208 / ASME B16.34

SERIE p.s.i.	PROVA IDROSTATICA		PROVA PNEUMATICA bar
	CORPO bar	TENUTA bar	
1000	104,0	76,0	6,0
3000	311,0	228,0	6,0
6000	621,0	456,0	6,0

SECONDO EN 12266-1 / ISO 5208 / EN ISO 17292 / API6D-ISO 14313 / ASME B16.34 / API598

CLASSE ANSI	PROVA IDROSTATICA		PROVA PNEUMATICA bar
	CORPO bar	TENUTA bar	
150	29,3	20,7	5,5
300	75,8	55,2	5,5
400	100,0	73,1	5,5
600	150,0	110,3	5,5
800 ^(*)	207,0	152,0	5,5
900	224,1	165,5	5,5
1500	372,3	275,8	5,5
2500	620,5	455,1	5,5

(*) Secondo EN ISO 17292 e BS 5351

